



Guyana Power & Light

Registered Offices:
Guyana Power & Light Inc.
40 Main Street
Georgetown
Guyana
Tel. No. 592-227-4482
Fax No. 592-225-5638

October 14, 2008

Prospective Bidders

**INVITATION FOR BIDS (IFB) GPL – PD-07-09/2008
PROCUREMENT OF SWITCHYARD MATERIALS, 69 KV SUB-STATIONS PROJECT**

ADDENDUM No. 6

Please find attached an addendum on the above contract. This addendum forms part of the contract and must be included in your bid submission.

Please acknowledge receipt of this addendum.

Should you require any further clarifications, do not hesitate to contact me.

Yours sincerely

GUYANA POWER & LIGHT INC.

Lennox McGregor

Lennox McGregor
Projects Manager

**INVITATION FOR BIDS (IFB) GPL – PD-07-09/2008
PROCUREMENT OF SWITCHYARD MATERIALS, 69 KV SUB-STATIONS PROJECT**

ADDENDUM No. 6

This addendum addresses clarifications requested on 14-10-08 and amendments to drawing reference numbers for the Sub-Stations Switchyard Lists for Lots 1 and 2, and now forms part of the bidding and contract documents and modifies the original bidding documents. Kindly acknowledge receipt of this addendum in the space provided in the Bid Submission Form.

Failure to do so may subject Bidder to disqualification.

AMENDMENT/CLARIFICATION OF LIST OF GOODS AND DELIVERY SCHEDULE, 69 KV Switchyard Materials.

1. **The following table below represents the amendments to drawing reference numbers for specific items of the Sub-Stations Switchyard Lists for Lots 1 and 2.**

LOT 2: SOPHIA SUBSTATION

QTY	DESCRIPTION	ITEM	LISTED DWG. NO.	CORRECT DWG. NO.
1	Outdoor group manual operated disconnect switch, with horn gaps, 69 kv, 3 pole, 60 hz, 600 A with 3 pole ground switch, for mounting on 7'-0" centres. Vertical break	2	5279-00-D-5C304	5279-00-D-5A134
2	Outdoor group manual operated disconnect switch, with horn gaps, 69 kv, 3 pole, 60 hz, 600 A, for mounting on 7'-0" centres. Vertical break	3	5279-00-D-5C304	5279-00-D-5C137

LOT 1: KINGSTON SUBSTATION

QTY	DESCRIPTION	ITEM	LISTED DWG. NO.	CORRECT DWG. NO.
6	Outdoor group manual operated disconnect switch, with horn gaps, 69 kv, 3 pole, 60 hz, 600 A with 3 pole ground switch, for mounting on 7'-0" centres. Vertical break	2	5279-00-D-5304	5279-00-D-5A134
4	Outdoor group manual operated disconnect switch, with horn gaps, 69 kv, 3 pole, 60 hz, 600 A, for mounting on 7'-0" centres. Vertical break	3	5279-00-D-5304	5279-00-D-5C137

2. The following points below address clarifications requested on 14-10-08:

1. All copies of drawings that were scanned have the same clarity. It is recommended that these drawings should be viewed with Adobe Software and with the application of the zoom command, all necessary information could be acquired. Please note that those PDF copies should not be used.
2. The quantity of 72.5 kV SF6 Breakers to be considered for the Lot 2 Sophia Sub-Station is two (2) as outlined in Addendum 4.
3. Addendum 2 refers to the Substations for which the listed items are included in their respective Switchyard Lists. Addendum 4 and 5 serve to displace Addendum 2.
4. Addendum 4 and Addendum 5 address two separate issues but serve to compliment each other. Addendum 4 addresses the amendments made to the Switchyard Lists for each of the individual Lots (1, 2 and 3). Thus, the quantities listed in Addendum 4 will be quantities for the individual items for each Sub-Station Lot to be priced in the Bid response. Addendum 5 addresses the technical specifications for the items listed in the individual Sub-Station Switchyard Lists (Lots 1, 2 and 3) in Addendum 4. Thus, the quantities for the individual items listed in Addendum 5 would represent the total quantity for the item when the individual quantities for the item for each Sub-Station are added.
5. For instructions to view/download drawing (No. 5279-00-D-5C135) contact Mr. Lennox McGregor (email: lmcgreggor@gplinc.com).